

Project Information

For:

Design Information

	Htg	Clg		Infiltration
Outside db (°F)	30	92	Method	Blower door
Inside db (°F)	70	75	Shielding / stories	3 (partial) / 1
Design TD (°F)	40	17	Pressure / AVF	50 Pa / 500 cfm
Daily range	-	M		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	13	49		

HEATING EQUIPMENT

Make	Carrier
Trade	BASE 13 PURON HP
Model	25HBA324A31
ARI ref no.	1179280
Efficiency	8.3 HSPF
Heating input	
Heating output	23800 Btuh @ 47°F
Temperature rise	28 °F
Actual air flow	767 cfm
Air flow factor	0.039 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	

COOLING EQUIPMENT

Make	Carrier
Trade	BASE 13 PURON HP
Cond	25HBA324A31
Coil	FX4CNF024
ARI ref no.	1179280
Efficiency	14.0 EER, 16.9 SEER
Sensible cooling	16100 Btuh
Latent cooling	6900 Btuh
Total cooling	23000 Btuh
Actual air flow	767 cfm
Air flow factor	0.058 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.77

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Bed 3	108	2645	1091	103	63
Bath	79	2096	586	81	34
Bed 2	124	1727	900	67	52
M Bath	51	862	216	33	13
Laundry	23	35	738	1	43
Kitchen	148	3446	4300	134	250
Living Room	288	4676	2257	181	131
Room9	104	163	171	6	10
Master B	184	4132	2951	160	171

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.

Entire House	1109	19783	13210	767	767
Other equip loads		2535	1095		
Equip. @ 0.97 RSM			13905		
Latent cooling			4193		
TOTALS	1109	22317	18098	767	767

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For:

Design Conditions

Location: Mobile, AL, US Elevation: 220 ft Latitude: 31 °N		Indoor: Indoor temperature (°F) 70 Design TD (°F) 40 Relative humidity (%) 30 Moisture difference (gr/lb) 13.2	Heating 70 40 30 13.2	Cooling 75 17 50 49.2
Outdoor: Dry bulb (°F) 30 Daily range (°F) - Wet bulb (°F) - Wind speed (mph) 15.0	Heating 30 - - 15.0	Cooling 92 17 (M) 77 7.5		
		Infiltration: Method Blower door Shielding / stories 3 (partial) / 1 Pressure / AVF 50 Pa / 500 cfm		

Construction descriptions

Walls

12C-0sw: Frm wall, wd ext, 1/2" wood shth, r-13 cav ins, 1/2" gypsum board int fnsh, 2"x4" wood frm

	Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
12C-0sw: Frm wall, wd ext, 1/2" wood shth, r-13 cav ins, 1/2" gypsum board int fnsh, 2"x4" wood frm	n	343	0.091	13.0	3.62	1241	2.30	789
	ne	22	0.091	13.0	3.62	80	2.30	51
	e	140	0.091	13.0	3.62	506	2.30	322
	se	20	0.091	13.0	3.62	73	2.30	47
	s	250	0.091	13.0	3.62	905	2.30	576
	w	211	0.091	13.0	3.62	765	2.30	486
12E-0sw: Frm wall, wd ext, 1/2" wood shth, r-19 cav ins, 1/2" gypsum board int fnsh, 2"x6" wood frm	all	986	0.091	13.0	3.62	3571	2.30	2270
	s	64	0.068	19.0	2.71	173	1.44	92

Partitions

(none)

Windows

Pella Energy Star U.30 S.28: Pella Energy Star U.36 S.30; NFRC rated (SHGC=0.30); 100% drapes, medium; foreground = new concrete (0.32); 6 ft overhang (5 ft window ht, 1.5 ft sep.)

Pella Energy Star U.30 S.28: Pella Energy Star U.36 S.30; NFRC rated (SHGC=0.30); 100% drapes, medium; 2 ft overhang (5 ft window ht, 1.5 ft sep.)	e	30	0.360	0	14.3	430	24.6	737
	s	30	0.360	0	14.3	430	9.12	274
	all	60	0.360	0	14.3	860	16.8	1011
Pella Energy Star U.33 S.31: Pella Energy Star U.33 S.31; NFRC rated (SHGC=0.31); 100% drapes, medium; foreground = new concrete (0.32); 8 ft overhang (5 ft window ht, 1.5 ft sep.)	e	20	0.330	0	13.1	263	18.7	374
	se	10	0.360	0	14.3	143	19.1	191
Pella Energy Star U.40 S.31: Pella Energy Star U.40 S.31; NFRC rated (SHGC=0.31); foreground = new concrete (0.32); 12.5 ft overhang (6.8 ft window ht, 1.3 ft sep.)	w	41	0.400	0	15.9	650	23.3	951
	e	21	0.140	7.1	5.57	117	4.24	89

Doors

Door, Reliablitt U.14 embossed: Door, Reliablitt U.14 embossed

Ceilings							
16CR-30ad: Attic ceiling, asphalt shingles roof mat, r-30 ceil ins, 1/2" gypsum board int fnsh	1109	0.032	30.0	1.27	1412	1.40	1554
Floors							
22A-vpm: Bg floor, heavy dry or light damp soil, vinyl flr fnsh	151	1.180	0	47.0	7103	0	0

Project Information

For:

Notes: comments here

Design Information

Weather: Mobile, AL, US

Winter Design Conditions

Outside db	30 °F
Inside db	70 °F
Design TD	40 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	49 gr/lb

Heating Summary

Structure	16143 Btuh
Ducts	3640 Btuh
Central vent (58 cfm)	2535 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	22317 Btuh

Sensible Cooling Equipment Load Sizing

Structure	10025 Btuh
Ducts	3185 Btuh
Central vent (58 cfm)	1095 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	13905 Btuh

Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 1
Pressure / AVF	50 Pa / 500 cfm

Latent Cooling Equipment Load Sizing

Structure	1519 Btuh
Ducts	737 Btuh
Central vent (58 cfm)	1938 Btuh
Equipment latent load	4193 Btuh

	Heating	Cooling
Area (ft²)	1109	1109
Volume (ft³)	8869	8869
Air changes/hour	0.27	0.15
Equiv. AVF (cfm)	39	22

Equipment total load	18098 Btuh
Req. total capacity at 0.70 SHR	1.7 ton

Heating Equipment Summary


Make	Carrier
Trade	BASE 13 PURON HP
Model	25HBA324A31
ARI ref no.	1179280
Efficiency	8.3 HSPF
Heating input	
Heating output	23800 Btuh @ 47°F
Temperature rise	28 °F
Actual air flow	767 cfm
Air flow factor	0.039 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	

Cooling Equipment Summary

Make	Carrier
Trade	BASE 13 PURON HP
Cond	25HBA324A31
Coil	FX4CNF024
ARI ref no.	1179280
Efficiency	14.0 EER, 16.9 SEER
Sensible cooling	16100 Btuh
Latent cooling	6900 Btuh
Total cooling	23000 Btuh
Actual air flow	767 cfm
Air flow factor	0.058 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.77

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.

Sheet 1



Job #: your job name
Performed by designer name for:

Your Contractor

Scale: 1 : 64
Page 1
Right-Suite® Universal
7.1.14 RSU09082
2009-Dec-04 09:48:33
D:_SBS_Files\Design Reviews\Mo...